

Fire Test Certificate

Friday June 10th, 2016

Supplier: Volume Supply Pty Ltd (29 Babbage Drive, Dandenong South, VIC 3175)

Sample Description: Prestige Range(TM)

Date Tested: June 2016

Test Method: ASISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

ASISO 9239-1:2003	Willy's Prestige
Critical Heat Flux/Critical Radiant Flux*	3.6 kW/m ²
Smoke Value*	19 %.min
Transitory flaming	Yes
Blistering	Yes
Penetration of flame through to substrate	Yes
Glowing	Yes

*Three test average value



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV160428