

Emission Test Certificate

Friday, 11th May 2018

Supplier: Volume Supply Pty Ltd (29 Babbage Drive, Dandenong South, VIC 3175)

Sample Description: Willy's Floor– Sandy Oak

Date Tested: April 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Design v3 IEQ-13	Willy's Floor– Sandy Oak
Total Volatile Organic Compound Emission Rate limit $<0.5 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.016 \text{ mg/m}^2/\text{hr}$
4-phenylcyclohexene Emission Rate limit <0.05 $\text{mg/m}^2/\text{hr}$	4-phenylcyclohexene Emission Rate: $<0.004 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate limit $<0.1 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $0.093 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV160428